



WIGGINS HOME INSPECTIONS, LLC

803-814-5621

wigginsinspections@gmail.com

<https://wigginsinspections.com>



WHI PRIVATE WELL WATER TEST SUMMARY

1234 Main Street
West Columbia , SC 29170

Buyer Name
10/29/2022 9:00AM



Inspector

Brandon Wiggins

RBI.49432 NACHI19061219

803-814-5621

wigginsinspections@gmail.com



Agent

Agent Name

555-555-5555

agent@spectora.com

TABLE OF CONTENTS

1: Private Well Water Test Summary

3

1: PRIVATE WELL WATER TEST SUMMARY

Information

Water Sample Details: Water Sample

Location

Kitchen

Kitchen Sink



Water sample taken from kitchen sink

Water Sample Details: Water Fixture Purged

Water fixture is purged of water for approximately 3-5 minutes before sample is taken.

Bacteria - Negative E&C

The water samples collected were found negative for coliform & E-coli. No additional actions required.

The lab reports were emailed along with this summary report as separate documents for your review and records.

Arsenic - Not Detected

The water sample collected was found to contain **less** than the lowest level detectable by the laboratory. The lowest limit is 0.5 ug/L, anything below this amount will be reported as **non-detectable=ND**. The EPA recommends maintaining lowest levels possible and recommends corrective action if levels exceed 10 ug/L, 10ppb or 0.010 mg/L. The link below has additional information regarding lead levels.

[Click here for additional information regarding Drinking Water Quality](#)

Lead - Acceptable Level

The water sample collected was found within acceptable Range or levels for lead. The lab report indicates levels, **(0.0018 fill in results)** mg/L. The EPA recommends levels not to exceed 15 ug/L, 15ppb or 0.015 mg/L. The link below has additional information regarding lead levels.

[Link for Additional Information about Lead in water](#)

Nitrate/Nitrite (No2&No3) - Not Detected

The water sample collected was found to contain **less** than the lowest level detectable by the laboratory. The lowest limit is 0.10 mg/L, anything below this amount will be reported as **non-detectable=ND**. The EPA recommends maintaining the lowest levels possible and recommends corrective action if levels exceed 10 mg/L, 10ppb or 0.010 ug/L. The link below has additional information regarding lead levels.

No additional actions recommended at this time. Lab reports will be supplied as separate documents for your records.

Links for additional information for regarding nitrate, nitrites or Nitrogen in the water:

[Click Here to access CDC info:](#)

[Click Here to access Water System Council info:](#)

[Click Here to access EPA info:](#)

Copy of link: <https://www.cdc.gov/healthywater/drinking/private/wells/disease/nitrate.html>

https://www.watersystemscouncil.org/download/wellcare_information_sheets/potential_groundwater_contaminant_information_sheets/Nitrate-and-Nitrite.pdf

<https://www.epa.gov/ground-water-and-drinking-water/national-primary-drinking-water-regulations#Inorganic>

SimpleLab Report & Recommendations

The Simple Lab Report were emailed along with this summary report as separate documents for your review and records.